



NOTES:

1. WHEN INSTALLING THIS UNIT, LOCAL , STATE, OR FEDERAL CODES SHOULD BE ADHERED TO FOR INSTALLATION DIMENSIONS (LOCATIONS), WASTE AND SUPPLY REQUIREMENTS, ETC.
2. TO COMPLY WITH ANSI Z358.1-2014 FOR EMERGENCY EYEWASH OR EYE/FACE WASH: EYEWASH OR EYE/FACE WASH SHALL BE POSITIONED SUCH THAT FLUSHING FLUID PATTERN IS NOT LESS THAN 33" (838mm) AND NO GREATER THAN 53" (1346mm) FROM SURFACE ON WHICH USER STANDS; AND 6.0" (153mm) MINIMUM FROM WALL OR NEAREST OBSTRUCTION.

3 EYEWASH HEAD ASSEMBLY MUST BE PARALLEL TO WALL OR OBSTRUCTION TO MEET CRITERIA STATED IN ACCORDANCE TO NOTES 1 AND 2.

*4. DIMENSIONS MAY VARY BY $\pm 1/2"$ (13 mm).

5. PRESSURIZE TO 100 PSI. REFILL IF PRESSURE BECOMES LESS THAN 95 PSI.

| | | | |
|---|--------------------------------|---|--------------------------------|
|  | | 1455 KLEPPE LANE SPARKS, NEVADA 89431 (775) 359-4712 FAX (775) 359-7424 E-MAIL: HAWS@HAWS.CO.COM WEBSITE: WWW.HAWS.CO.COM | |
| | | ECN NO. REVISED PER BY: MODEL(S) ECN: 5438 FV: 7601.37 | PART NUMBER 0002080061.D |
| DRAWN: RTM DATE: 7/24/03 CHKD.: DP | APPROVED: IR DATE: 12/09/19 | SCALE: 1:10 DRAWING TYPE: INSTALLATION | REVISION 18 SHEET 1 OF 1 |